



SCHEDULE "C"

Application For Sewer Service Permit

Original to Foreman

FEE: \$100.00

Permit # _____

Name of Applicant		Date of Application	
Name of Property Owner (if available)		Phone Number	
Current Address of Owner			
Plumber		Phone Number	
Lot No.		Building Permit No.	
Subdivision		Plumbing Permit No.	
Street		Water Permit No. (if applicable)	
Feasibility of Installation:		Foreman's Signature	
REQUIREMENTS FOR INSTALLATION OF SEWER LATERAL			
<ol style="list-style-type: none"> 1) The diameter of the sewer lateral for Residential properties shall not be less than four (4) inches and pipe installed for Commercial, Institutional or Industrial properties shall not be less than six (6) inches. 2) Pipe material shall be PVC SDR35 with rubber gasket joints. 3) Pipe shall be laid with not less than ¼ inch per foot grade, with a six (6) inch bed of clear stone, with twelve (12) inches of clear stone over the pipe. 4) Backwater valves must be installed as per the National Plumbing Code 1995, Section 4.6.4. 5) Sewer lateral to be capped during construction, to prevent storm water from entering system. 6) The contractor shall notify the Utility Inspector when the lateral is ready to be connected to the main sewer line. The lateral shall remain uncovered until inspected. 7) The contractor shall notify the Utility Inspector when the backwater valves are installed on the building drain inside the foundation wall. 			
The undersigned owner of agent makes application to enter the Town of St. George Sewer System. I agree to adhere to the following stipulations, which form, in part, the Sewerage Utility Bylaw No. 27-C.			
Owner or Agent		Telephone	
Address		Date	

OFFICE USE ONLY

Regarding the above Application:

This is to certify that I have inspected the Building Sewer INSTALLATION and CONNECTION to the Town of St. George and find that it meets the requirements of the Town Bylaw No. 27-C.

Connection Fee: \$ _____

Inspector	Inspection Date
-----------	-----------------

*** Foreman to make sure everything on forms is properly filled in and must sign.**